


Maheshkumar R. Mod

Regional Fire Officer



Gujarat State Fire Prevention Services

State Fire Prevention Service

Block no 14/3, GH Type,

Sector-22, Gandhinagar

Mobile No.+91 94279 55551

Email :- rfogandhinagar101@gmail.com

"WE SERVE TO SAVE"

SFPS/FIRE NOC/R-5/005/2022

Date: 18-01-2022

Fire Safety Certificate

Certified that the **Cosmos Castle International School Green Campus**, Survey No-684, Godhavi Gam, Manipur Road Ta.Sanand, Dist. Ahmedabad comprised School (B+G+2) owned/occupied by **Ramdulari Dhansiram Agrasen Charitable Trust** of have complied with the fire prevention and fire safety requirements in accordance with section 18 and verified by the officers concerned of Fire Service on Dt.13-01-2022 in the presence of Apple Fire & Safety and the School premises is fit for occupancy with effect from for a period of **(from Dt. 18-01-2022 to Dt. 17-01-2025)** years in accordance with rules and subject to compliance of any specific laid by the issuing officer.

Place: Gandhinagar

Issued Dt.18-01-2022.

નોંધ : બેઝમેન્ટનો વપરાશ બી.યુમાં દર્શાવ્યા મુજબ કરવાનો રહેશે.અન્યથા આગ અકસ્માત જેવી કોઈ ઘટના દરમીયાન કોઈ જાનહાની કે નુકસાન થશે તો તેની સઘળી જવાબદારી વહીવટી કર્તાની રહેશે



M. R. Mod
18/01/2022

Regional Fire Officer

State Fire Prevention Services

Gandhinagar Region

Chalan No. (2500)-2069

Chalan No. (1000)- 2070

- 1) The main gate is to be wide enough to let fire vehicle in the campus and should be kept open.
- 2) Fire equipment to be kept handy and in a manner easily accessible.
- 3) All emergency numbers should be displayed outside the office.
- 4) The primary training will have to be given to all employees to use the fire extinguishing system in difficult circumstances and the certificate will have to be obtained and submitted.
- 5) Students studying in the school should also be given basic training on how to rescue in case of fire.
- 6) Roads leading to the school must be kept open.
- 7) Use of basement(If) must be done as per B.U. permission.
- 8) No road or dome of any kind should be built on the roof.
- 9) No more than 40 students in a classroom.
- 10) Class room and Evacuation routes should be kept open and should not be blocked.
- 11) There should be no storage of scrap material in school campus.
- 12) The school shall comply with all fire and safety regulations and guidelines issued by the concerned and competent authority.
- 13) In any case, care should be taken to ensure that ventilation and exit routes are directly or indirectly accessible for all.
- 14) The canteen shall be kept away from the school building